



Date Submitted: 4/20/2022

Water Use Efficiency Annual Performance Report - 2021

WS Name: MILTON CITY OF

Water System ID# : 54950

WS County: PIERCE

Report submitted by: *Dustin Sloan*

Meter Installation Information:

Estimate the percentage of metered connections: 100%

If not 100% metered – Did you submit a meter installation plan to DOH? No

Within your meter installation plan, what date did you commit to completing meter installation?

Current status of meter installation:

Production, Authorized Consumption, and Distribution System Leakage Information:

12-Month WUE Reporting Period 12/16/2020 To 12/15/2021

Incomplete or missing data for the year? No

If yes, explain:

Total Water Produced & Purchased (TP) – Annual volume gallons	363,617,000 gallons
Authorized Consumption (AC) – Annual Volume in gallons	327,530,783 gallons
Distribution System Leakage – Annual Volume TP – AC	36,086,217 gallons
Distribution System Leakage – DSL = $[(TP - AC) / TP] \times 100 \%$	9.9 %
3-year annual average - %	8.4 % 2019, 2020, 2021

Goal-Setting Information:

Enter the date of most recent public forum to establish WUE goal: 07/06/2010

Has goal been changed since last performance report? Yes

Note: Customer goal must be re-established every 6 years through a public process.

Customer WUE Goal (Demand Side):

The city is looking to reduce customer water usage by 3% over the next 10 years.

Customer (Demand Side) Goal Progress:

The goal was just established this April 2021. Non data to report

Additional Information Regarding Supply and Demand Side WUE Efforts